## Investing in HVAC System Maintenance

Typical useful lives and maintenance requirements for major HVAC plant equipment, based on DOE analyses, manufacturer recommendations and common practice.

	LIFETIME (run hours)	MAJOR OVERHAUL (% of first cost/interval)	MINOR OVERHAUL (% first cost/interval)	ANNUAL MAINTENANCE (person-hours per year)
Boiler	220,000	10%/ 50,000 hours	4%/ 10,000 hours	8-12
Chiller	100,000	10%/ 50,000 hours	5%/ 20,000 hours	25-40
Cooling tower	100,000	25%/ 50,000 hours	10%/ 5,000 hours	40-80
Air handler	100,000	varies widely	varies widely	4-8