

PUE Reduction Snapshot

2004

	KW
Building load	1,230
“Office” load	(71)
Data center building load *	1,159
UPS load	564
PUE **	2.05

** Data center building load equals building load minus “office” load.*

*** PUE equals data center building load divided by UPS load.*

2008

	KW
Building load	1,549
“Office” load	(71)
Data center building load *	1,478
UPS load	855
PUE **	1.73

Energy savings over one year

Energy savings in KW	171
One year savings in kWh	1,497,960
Electricity cost at .05 per kWh	\$74,898