## Efficiency plans for future projects

- Definitely planned for construction/ renovation expected to start in next three years
- Will be seriously considered for those projects

Control temperature on supply rather than return air

50%

Hot aisle/cold aisle

26%

VFDs/controls to enable part-load HVAC operation

52%

Economizer cycle

33% 42%

New ASHRAE temperature guidelines

53% 29%

Energy efficient IT equipment guidelines

50%

Server virtualization

39% 39%

SOURCE: BUILDING OPERATING MANAGEMENT SURVEY